


#### **JE/PHE/EE/II/24**

GET IT ON **Google Play** 



/48

[ No. of Questions : 100

# Test Prime

# ALL EXAMS, ONE SUBSCRIPTION



50,000+ Mock Tests



500+ Exam Covered



Personalised Report Card



Previous Year Papers



Unlimited Re-Attempt



500% Refund



# **ATTEMPT FREE MOCK NOW**



- 1. A wire of length l and of circular cross-section of radius r has a resistance of R ohm. Another wire of same material and crosssectional radius 2r will have same resistance R, if the length is
  - (A) 21
  - (B) 41
- (C)  $\frac{l}{2}$

(D)

- 2. Which of the following materials possesses the least resistivity?
  - (A) Iron
  - (B) Manganin
  - (C) Copper
  - (D) Aluminium

3. An electric bulb can be worked from

- (A) AC supply
- (B) DC supply
- (C) battery supply only
- (D) All of the above
- 4. Which of the following is an active element of a circuit?
  - (A) Resistance
  - (B) Inductance
  - (C) Capacitance
  - (D) Ideal current source

JE/PHE/EE/II/24**/48-A** 

- 5. If two incandescent light bulbs of 40 W and 60 W ratings are connected in series across the main supply, then
  - (A) the bulbs together consume 100 W
  - (B) the bulbs together consume 50 W
  - (C) the 60 W bulb glows brighter
  - (D) the 40 W bulb glows brighter
- **6.** A network has 4 nodes and 3 independent loops. What is the number of branches in the network?
  - (A) 6
  - (B) 5
  - (C) 7
  - (D) 8
- 7. Superposition theorem can be applicable to only
  - (A) linear network
  - (B) linear bilateral network
  - (C) non-linear network
  - (D) bilateral network
- 8. An inductor stores energy in what form?
  - (A) Electrostatic field
  - (B) Electromagnetic field
  - (C) Magnetic field
  - (D) Core
- 2





- **9.** Kirchhoff's current law at a junction deals with
  - (A) conservation of energy
  - (B) conservation of charge
  - (C) conservation of momentum
  - (D) conservation of power
  - 10. Two heaters, rated at 1 kW, 250 V each, are connected in series across a 250 V, 50 Hz AC mains. The total power drawn from the supply would be

    - (B) 1000 W
    - (C) 250 W
    - (D) 2000 W
- 11. Two electric bulbs rated for same voltage have powers of 200 W and 100 W. If their resistances are respectively  $R_1$  and  $R_2$ , then
  - (A)  $R_1 = 2R_2$  (A)
  - (B)  $R_2 = 2R_1$
  - (C)  $R_2 = 4R_1$
  - (D)  $R_1 = 4R_2$  AV (128) (G)

JE/PHE/EE/II/24/48-A

- **12.** For maximum power transfer theorem, the value of maximum power is
  - (A)  $P_{\text{max}} = V_{\text{th}}^2 / 2R_{\text{th}}$
  - (B)  $P_{\text{max}} = V_{\text{th}} / 2R_{\text{th}}$
  - (C)  $P_{\text{max}} = V_{\text{th}}^2 / 4R_{\text{th}}$
  - (D)  $P_{\rm max} = V_{\rm th}^2 / 4R_{\rm th}^2$
- **13.** The average power in a pure inductive circuit is
  - (A) 0
  - (B) *VI*
  - (C)  $VI\cos\phi$
  - (D)  $\sqrt{3} VI \sin \phi$

14. When a series *R-L* circuit is connected to a voltage source *V* at t = 0, the current passing through the inductor *L* at  $t = 0^+$  is


(A) V/L

3

- (B) infinite
- (C) V/R
- (D) 0



- **15.** A passive element in a circuit is one which
  - (A) supplies energy
  - (B) receives energy
  - (C) Both supplies and receives energy
  - (D) None of the above
- **16.** An ideal voltmeter connected across the terminals A and B is shown in the figure below :



- It will read
- (A) 64 V
- (B) 4 V
- (C) 48 V
- (D) 12 V
- 17. When a network is loaded by a resistance equal in value to the Norton's resistance, the network current is  $I_N$ . The current through the load will be
  - (A)  $I_{\rm N}/4$
  - (B)  $2I_N$
  - (C)  $I_{\rm N} / 2$
  - (D) None of the above

JE/PHE/EE/II/24/48-A

- **18.** In parallel *L-C* circuit, what will be the value of current (in ampere) at resonance?
  - (A) 0
  - (B) 10
  - (C) 100
    - second in column and the
  - (D) Infinite
- **19.** What is the correct expression for form factor of a pure sinusoidal signal?
  - (A) Product of  $I_{\rm rms}$  and  $I_{\rm avg}$
  - (B)  $I_{\rm avg}/I_{\rm rms}$
  - (C)  $I_{\rm rms}/I_{\rm avg}$
  - (D) None of the above
- **20.** For a certain load, the real power is 100 W and the reactive power is 100 VAR. The apparent power is
  - (A) 100 VA
  - (B) 120 VA
  - (C) 141·4 VA
  - (D) 250 VA



**21.** Commutation in a DC machine may be improved by

**Adda**[24]7

- (A) reducing the number of turns in the armature and segments of commutator
- (B) increasing the resistance of brushes
- (C) neutralizing the reactance voltage by producing a reverse e.m.f. in the coil undergoing commutation
- (D) All of the above
- 22. The maximum number of brushes which may be used in an electrical machine is equal to
  - (A) number of poles in the machine

  - (C) 4
  - (D) Either (A) or (B)

23. \_\_\_\_ DC machines are most common.

- (A) 2-pole
- (B) 4-pole
- (C) 6-pole
- (D) 8-pole

24. The voltage equation of a DC motor

- is
- $(A) \quad V = V_b + I_a R_a$
- (B)  $V = V_b I_a R_a$

$$(C) \quad V = V_b - \frac{1}{2} I_a R_a$$

(D) 
$$V = V_b + \frac{1}{2}I_a R_a$$

JE/PHE/EE/II/24/48-A

- 25. A separately excited DC generator is *not* used because
  - (A) it is costly
  - (B) separate DC source is required for field circuit
  - (C) voltage drops considerably with load
  - (D) None of the above
- **26.** The efficiency of a DC generator is maximum when its variable loss is equal to
  - (A) the constant loss
  - (B) half of the constant loss
  - (C) double of the constant loss
  - (D) None of the above
- 27. The mechanical power developed in a DC motor is maximum when the back e.m.f.  $(E_b)$  is equal to \_\_\_\_\_ of the applied voltage.
  - (A) twice
  - (B) half
  - (C) one-third
  - (D) None of the above
- **28.** DC shunt motors are used in those applications where \_\_\_\_\_ is required.
  - (A) high starting torque
  - (B) practically constant speed
  - (C) high no load speed
  - (D) variable speed

A-891 P.T.O.





- 29. Which motor should not be used for centrifugal pump?
  - (A) Shunt
  - (B) Series
  - (C) Cumulative compound
  - (D) Differential compound
- 30. A 400 kW, 3-\$, 440 V, 50 Hz induction motor has a speed of 950 r.p.m. on full load. The motor has 8 poles. The slip of the motor will be
  - (A) 0.01
  - (B) 0.04

  - (C) 0.05
  - (D) 0.06

  - 31. What is the primary reason for placing field on rotor in an alternator?
    - (A) Small power in the field circuit
    - (B) Insulation of high voltage is made easy on stator than on o rotor according (A)
    - (C) Large power in stator
      - (D) Large current in stator

#### JE/PHE/EE/II/24/48-A

- 32. Slip ring motor is recommended when
  - (A) speed control is required
- (B) frequent starting, stopping and reversing are required
  - (C) high starting torque is required
  - (D) All of the above

33. In case of voltage injection method of speed control, the injected e.m.f. should be of

- (A) (1-s)f
- (B) (2-s)f
- (C) slip frequency (sf)
- (D) supply frequency (f)

34. Two series motors are mechanically coupled. One machine is run as a motor and other as a generator. The iron and friction losses of the machines will be identical when

- (A) their speeds are identical
- (B) their speeds and excitations are identical
  - (C) their speeds are equal but back e.m.f. is the half of the supply voltage
  - (D) their rating and armature size are equal





- **35.** A DC series motor is running at rated speed without any additional resistance in series. If an additional resistance is placed in series, then the speed of the motor
  - (A) increases
  - (B) decreases
  - (C) remains same
  - (D) None of the above
- **36.** Is it possible to have current in a transmission line under no load condition?
  - (A) Yes, because of capacitance effect
  - (B) No, because of proximity effect
  - (C) Yes, because of corona effect
  - (D) Yes, because of skin effect

**37.** If the AC supply to transformer is replaced by DC, then

- (A) the primary winding will burn
- (B) the secondary winding will burn
- (C) the transformer has no effect
- (D) All of the above
- **38.** A load draws an active power P at a lagging power factor  $\cos \phi_1$ . If the p.f. is improved to  $\cos \phi_2$ , then the leading kVAR supplied by p.f. correction equipment will be
  - (A)  $P(\cos \phi_2 \cos \phi_1)$
  - (B)  $P(\sin \phi_2 \sin \phi_1)$
  - (C)  $P(\tan\phi_1 + \tan\phi_2)$
  - (D)  $P(\tan\phi_1 \tan\phi_2)$

JE/PHE/EE/II/24/48-A

- **39.** In order to reduce the cost of generation of electrical energy, the value of diversity factor (DF) and load factor (LF) should be
  - (A) both DF and LF high
  - (B) LF low and DF high
  - (C) LF high and DF low
  - (D) both LF and DF low
- **40.** In a power transformer, the breather is provided in order to
  - (A) filter transformer oil
  - (B) prevent ingress of moisture with air
  - (C) provide oxygen to the cooling oil
  - (D) provide fresh air for increasing cooling effect
- **41.** A given amount of power is to be transmitted over a certain distance with fixed power loss. The volume of the copper required (transmission voltage = V, load p.f. =  $\cos \phi$ ) is
  - (A) directly proportional to V
  - (B) inversely proportional to V
  - (C) proportional to  $(1/V^2 \cos^2 \phi)$
  - (D) proportional to  $V^2 \cos^2 \phi$
- **42.** In order to improve p.f. in case of a 3-phase load, the capacitors are connected in
  - (A) delta
  - (B) star

7

- (C) star or delta
- (D) None of the above





- 43. Fleming's left-hand rule is applicable
- generation of electrical consyst he
  - (A) DC generator
  - (B) DC motor
  - (C) alternator
  - (D) transformer
- **44.** The purpose of the conservator in a transformer is
  - (A) to cool the winding
  - (B) to prevent moisture in the transformer
  - (C) to prevent short circuit of primary and secondary winding
  - (D) to take up contraction and expansion of oil
- **45.** A magnetic circuit mainly consists of a material having permittivity
  - (A) high
  - (B) low
  - (C) medium
  - (D) constant
- **46.** Cogeneration is the simultaneous generation of
  - (A) heat and power
  - (B) mechanical energy and power
  - (C) steam and condensate
  - (D) All of the above
- JE/PHE/EE/II/24**/48-A**

- 47. Hydroelectric power plant is
- (A) non-renewable source of energy
  - (B) conventional source of energy
  - (C) non-conventional source of energy
  - (D) continuous source of energy
  - 48. Load curve helps in deciding
    - (A) total installed capacity of plant
    - (B) sizes of the generating units
    - (C) operating schedule of the generating units
    - (D) All of the above
  - **49.** A feeder in a transmission system feeds power to
    - (A) generation station
    - (B) distributors
    - (C) service mains
    - (D) All of the above
- **50.** The benefit of SCADA in power system is
  - (A) improved quality of service
  - (B) improved reliability
  - (C) Both of the above
  - (D) None of the above





- **51.** The equal area criterion of stability is used for
  - (A) no load on the busbar
  - (B) one machine and infinite busbar
  - (C) more than one machine and infinite busbar
  - (D) None of the above
- **52.** The transient stability limit of the power system can be increased by introducing

63. The difference between the indice

- (A) series inductance
- (B) shunt inductance
- (C) series capacitance
- (D) shunt capacitance
- 53. The relative permeability of paramagnetic material is
  - (A) one
  - (B) less than one
  - (C) little more than one
  - (D) several hundred
  - **54.** Which of the following materials is particularly suitable for use in standard resistance coil and instrument shunts?
    - (A) Nichrome
    - (B) Graphite
    - (C) Manganin
    - (D) Alnico

JE/PHE/EE/II/24/48-A

- 55. Polarization P in a solid dielectric is related to the electric field E and electric flux density D by the relation
  - (A)  $E = P + \varepsilon_0 D$
  - (B)  $D = E + \varepsilon_0 D$
  - (C)  $D = \varepsilon_0 E + P$
  - (D)  $D = \varepsilon_0 P + E$
- **56.** The acceptance value of grounding resistance to domestic appliance is
  - (A) 0·1Ω
  - (Β) 1Ω
  - (C) 10 Ω
  - (D) 100 Ω
- 57. An ideal OP-AMP has
  - (A) infinite  $A_v$
  - (B) infinite R<sub>i</sub>
  - (C) zero R<sub>o</sub>
  - (D) All of the above

58. LEDs normally work on a voltage of

- (A) 1 V to 2 V
- (B) 10 V to 20 V
- (C) 50 V to 60 V


9

(D) 100 V to 150 V



**59.** The characteristics of thyristor closely resemble to the characteristics of

- (A)' *P-N* junction
- (B) constant voltage source
- (C) constant current source
- (D) thyratron gas tube
- **60.** The Class B push-pull amplifier has the advantage of being free from
  - (A) any circuit imbalance
  - (B) unwanted noise
  - (C) even-order harmonic distortion
  - (D) DC magnetic saturation effect
- 61. The following figure represents a/an



(A) N-P-N transistor

- (B) P-N-P transistor
- (C) Zener diode
- (D) power diode

JE/PHE/EE/II/24/48-A

- **62.** The instrument used for DC measurement alone is
  - (A) moving-iron type
- (B) electrodynamic type
  - (C) permanent magnet type
  - (D) induction type

**63.** The difference between the indicated value by an instrument and true value of a variable is called

- (A) dead zone error
- (B) relative error
- (C) static error
- (D) drift error
- **64.** Which of the following instruments consumes the lowest power measurement?
  - (A) VTVM
  - (B) PMMC instrument
  - (C) Electrostatic instrument
  - (D) d'Arsonval instrument
- **65.** The phenomenon of creeping occurs in
  - (A) ammeter
  - (B) energy meter
  - (C) wattmeter
  - (D) voltmeter



- 66. CRO is used to measure
  - (A) phase
  - (B) frequency
  - (C) voltage
  - (D) All of the above
- **67.** Hay's bridge is particularly suited for measurement of
  - dam od bluoria nat grilloo off
  - (A) capacitance over a wide range of values
  - (B) inductance having high Q-value
  - (C) capacitance having high Q-value
  - (D) inductance having low Q-value
- **68.** The number 1000<sub>2</sub> is equivalent to decimal number
  - (A) one thousand
  - (B) eight
  - (C) four
  - (D) sixteen


# **69.** The cumulative addition of the four binary bits (1+1+1+1) gives

JE/PHE/EE/II/24/48-A


**70.** The 2's complement of  $1000_2$  is


	(A)	1000		ntially	
	(B) 0001				
		0001	001	0038	
	(C)	0111		68000	
	(D)	0101			
	• •				

# **71.** The output of the logic circuit given below represents \_\_\_\_\_ gate.



# **72.** Determine the output expression for the circuit shown below :





Adda 247



- **73.** Microprocessor 8085 is the enhanced version of \_\_\_\_\_ with essentially the same construction set.
  - (A) 6800
  - (B) 68000
  - (C) 8080
  - (D) 8000
- 74. In computer parlance, 'handshaking' means
  - (A) checking the status register
  - (B) controlling the information exchange via I/O ports between microcomputer and external logic
  - (C) data transmission by external logic to I/O port
  - (D) reading I/O port data by a microprocessor

#### 75. Switchgear is a device used for

- (A) interrupting an electrical circuit
- (B) switching an electrical circuit
- (C) switching and controlling an electrical circuit
- (D) switching, controlling and protecting the electrical circuit and equipment

#### 76. An isolator is installed

- (A) to operate the relay of the circuit breaker (CB)
- (B) as a substitute for CB
- (C) always independent of the position of CB
- (D) generally on both sides of a CB

#### JE/PHE/EE/II/24/48-A

- 77. Resistance grounding is used for voltage between
  - (A) 33 kV to 66 kV
  - (B) 11 kV to 33 kV
  - (C) 3.3 kV to 11 kV
  - (D) None of the above
- **78.** No ceiling fan should be installed at the height of less than
  - (A) 2.5 m from the floor
  - (B) 5.5 m from the floor
  - (C) 4.5 m from the floor
  - (D) 3.5 m from the floor
- **79.** The frequencies and voltage used in dielectric heating are
  - (A) 10 MHz-30 MHz up to 25 kV
  - (B) 50 MHz-60 MHz up to 25 kV
  - (C) 10 MHz-30 MHz up to 100 V
  - (D) 50 MHz-60 MHz up to 230 V
- **80.** The loads on 3-phase, 4-wire distributor are usually
  - (A) balanced
  - (B) unbalanced
  - (C) either balanced or unbalanced
  - (D) None of the above



- **81.** When the length of cable increases, its capacitance
  - (A) decreases
  - (B) increases
  - (C) remains same
  - (D) None of the above
- 82. A wattmeter measures \_\_\_\_\_ power.
  - (A) instantaneous
  - (B) apparent
  - (C) reactive
  - (D) average

**83.** 8085 is capable of addressing \_ of memory.

- (A) 8K
  - (B) 16K
  - (C) 24K
  - (D) 64K

**84.** How many buses are connected as a part of 8085 microprocessor?

- (A) 2
- (B) 3
- (C) 5
- 10.00
- (D) 8

JE/PHE/EE/II/24/48-A

- 85. The material used for fuse must have
  - (A) low melting point and high specific resistance
  - (B) low melting point and low specific resistance
  - (C) high melting point and low specific resistance
  - (D) low melting point and any specific resistance
- **86.** Which IE rule is applicable to service mains?
  - (A) Rule 30
  - (B) Rule 33
    - 121.1.110
  - (C) Rule 77
  - (D) All of the above

87. Which among the following fuses is very fast in operation?

- (A) Semiconductor fuse
- (B) High rupturing capacity fuse
- (C) Kit Kat fuse
- (D) Cartridge fuse

[ P.T.O.



88. Steel rail poles of height 13 meters are used for transmission purpose of \_\_\_\_\_ voltage.

\_\_\_\_\_

- (A) 33 kV
- is principal and and
- (B) 11 kV
- (C) 22 kV
- (D) Both (A) and (B)
- **89.** On which of the following, routine tests are conducted?
  - (A) Oil circuit breakers (CBs)
  - (B) Air blast CBs
  - (C) Minimum oil CBs
  - (D) All of the above

**90.** Which among the following is a commissioning check during site testing for an induction motor?

- (A) Insulation resistance
- (B) Terminal shrouds
- (C) Heater supply
- (D) All of the above

JE/PHE/EE/II/24/48-A

- **91.** In monthly maintenance of storage batteries, which activity is performed?
  - (A) Voltages
  - (B) Cleaning
  - (C) Terminals
  - (D) All of the above

**92.** In annually inspection, which is mainly inspected in less than 100 kVA transformer?

- (A) Fire system
- (B) Core
- (C) Coil
- (D) Oil

**93.** In annually inspection, which is mainly inspected in overhead line?

- (A) Insulation
- (B) Tower
- (C) Earth wire
- (D) All of the above
- **94.** Which of the following is **not** a type of electric resistance welding?
  - (A) Butt welding
  - (B) Seam welding
  - (C) Helium welding
  - (D) Spot welding



95. Biogas mainly consists of

- (A) fossil
- (B) cow dung
- (C) petroleum
- (D) All of the above
- **96.** Which of the following is a conventional source of energy derived from decayed plant and animal remains?
  - (A) Wind
  - (B) Geothermal
  - (C) Solar
  - (D) Coal
- **97.** Which non-conventional source of energy involves tapping into the Earth's internal heat for power generation?
  - (A) Solar energy
  - (B) Wind energy
  - (C) Geothermal energy
  - (D) Tidal energy

JE/PHE/EE/II/24/48-A

- **98.** For any medium, electric flux density D and electric intensity E are related as
  - (A)  $D = \varepsilon_0 E$
  - (B)  $D = \varepsilon_0 / E$
  - (C)  $D = E / \varepsilon_0 \varepsilon_r$
  - (D)  $D = \varepsilon_0 \varepsilon_r E$
- **99.** Most of single-phase induction motors are \_\_\_\_\_ machines.
  - (A) 2-pole
  - (B) 6-pole
  - (C) 8-pole
  - (D) 4-pole
- 100. A synchronous motor of reactive power when

delivers

- (A) over-excited
- (B) under-excited
- (C) normally excited
- (D) None of the above

15



# SPACE FOR ROUGH WORK

(A) forcall

B) cow dung

(2) D = 0 (2)

Which of the following is a Conventional serves of secret define frim decry i piant and animal semants?

JE/PHE/EE/II/24 <b>/48-A</b>			16	24T-425×4
			* * *	
				(C), familiermeil wife ge-
		believe-vslant		<ul> <li>Valencia anti M. 16</li> </ul>
				<ul> <li>S.Z. V Ref. Phys. mat. Letter (1990).</li> <li>Martin Valenti fumore (1990).</li> <li>Barbi is material (1990).</li> </ul>
		doguđe		
		share share		
SEAL				
S				

SEAL